

INVITATION TO TENDER No 9/2024

Supply of ventilation equipment and construction work required for the installation of mechanical ventilation in the building premises industry for the planned start-up of a new production line for converting PET flake into pellets.

I. NAME AND ADDRESS OF THE CONTRACTING AUTHORITY

Aloxe Gdynia Sp. z o.o.
8 Hullovce Street
81-336 Gdynia
Poland

II. QUESTIONS AND ANSWERS

Lp.	Date of question	Content of the question	Date of reply	Content of the reply
1	05.09.2024	<p>Please confirm that the Investor allows the change:</p> <ol style="list-style-type: none"> Ducted fans to roof-mounted fans. The rationale for the change is due to better access to the building's roof-mounted equipment. <p>In addition, please confirm that the scope of the bid should include:</p> <ol style="list-style-type: none"> Roof openings and roof flashing of the openings made? Supporting structure for ventilation ducts and hood? 	09.09.2024	<p>Answers:</p> <ol style="list-style-type: none"> The client is making the change from duct fans to roof fans, with the adaptation of the design and execution of the As-built documentation is the responsibility of Performers. Roof openings must be included in the bid and roofing treatment of the holes made. The bid should include the support structure for the ventilation ducts and the eaves.